

Recommended Practice for Installation and Operation of Wet Steam Generators

API RECOMMENDED PRACTICE 11T
SECOND EDITION, NOVEMBER 1, 1994

American Petroleum Institute
1220 L Street, Northwest
Washington, D.C. 20005



Recommended Practice for Installation and Operation of Wet Steam Generators

Exploration and Production Department

API RECOMMENDED PRACTICE 11T
SECOND EDITION, NOVEMBER 1, 1994

**American
Petroleum
Institute**



SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Authoring Department [telephone (214) 953-1101]. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an *API standard*. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the director of the Exploration and Production Department, American Petroleum Institute, 700 North Pearl, Suite 1840, Dallas, Texas 75201. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

CONTENTS

	PAGE
1 SCOPE	1
1.1 Introduction	1
1.2 Rating	1
1.3 Components	1
2 SPECIFICATIONS	1
2.1	1
2.2 Applicable and Standards	1
2.3 Rating and Efficiency	1
2.4 Special Considerations	2
2.5 Safety Equipment	3
2.6 Aesthetics	3
2.7 Hook-Up	4
3 INSTALLATION	4
3.1 Inspection for Shipment Damages	4
3.2 Foundation	4
3.3 Heavy Lifting Services	4
3.4 Removal of Shipment Braces and Protective Covers	4
3.5 Water and Steam Connections	4
3.6 Fuel Connections	4
3.7 Waste Discharge Connections	4
3.8 Blow Down Discharge Connection	4
3.9 Pilot Fuel Connections	4
3.10 Electrical Connections	4
3.11 Air Supply Connections	5
3.12 Manufacturer Supplied Data	5
4 COMMISSIONING	5
4.1	5
4.2 Lube Oil Levels	5
4.3 Pulsation Dampener Charge	5
4.4 Motors	5
4.5 Compressor	5
4.6 Water-Steam Piping System	7
4.7 Fuel Oil System	7
4.8 Fuel Gas System	7
4.9 Initial Firing	7
4.10 Drying Out Refractory	7
4.11 High Rate Burner Adjustments	8
4.12 Burner Positioner	8
4.13 Safety Shut Down Devices	8
4.14 Flow-Pressure Burner Controls	8
4.15 Efficiency Check	8
5 OPERATIONS	8
5.1	8
5.2 Start-Up Procedures	8
5.3 Adjusting the Wet Steam Generator for Unattended Operation	9
5.4 Shutdown Procedures	9
6 MAINTENANCE	10
6.1	10

6.2	Daily Maintenance and Inspection	10
6.3	Monthly Maintenance and Inspection	10
6.4	Safety Inspection	10
6.5	Annual Maintenance and Inspection.....	11
APPENDIX A—WET STEAM GENERATOR FEEDWATER QUALITY		19
APPENDIX B—WET STEAM GENERATOR EMISSIONS CONTROL		21
APPENDIX C—WET STEAM GENERATOR FUEL OIL		23
APPENDIX D—FACTORS FOR CONVERSION TO INTERNATIONAL SYSTEM OF UNITS (SI)		25
Figures		
1	—Example Heat Balance Performance Data Sheet	6
2	14
Tables		
1	—Fuel Oil Analysis	2
2	—Fuel Gas Analysis	3
3	—Water Analysis	3
4	—Example Mechanical Design Data Sheet	5
5	—Wet Steam Generator Daily Log	12
6	—Monthly Maintenance and Inspection Example Wet Steam Generator Check List.....	12
7	13
8	—Wet Steam Generator Safety Inspection Check Sheet.....	13
9	—Wet Steam Generator Annual Check List.....	15
10	—Record of Welded Repairs.....	17

FOREWORD

This recommended practice is under the jurisdiction of the American Petroleum Institute (API) Committee on Standardization of Production Equipment.

This standard shall become effective on the date printed on the cover but may be used voluntarily from the date of distribution.

Recommended Practice for Installation and Operation of Wet Steam Generators

1 Scope

1.1 INTRODUCTION

1.1.1 The Wet Steam Generator used in enhanced oil recovery is a forced circulation once-through design. It is also known by many other common names such as thermal recovery heater, oil field heater, etc. The once-through design enables the use of water essentially free of hardness and suspended solids, but of relatively high total dissolved solids. The equipment normally uses a fixed water flow system with some modulation capabilities for reduced output. The equipment does not contain drums or level controls, which are normally associated with stationary boilers. The Wet Steam Generator can be designed for installation in environments found in oil production areas of the world. Minimum operator attention is required.

1.1.2 For the most common sizes of Wet Steam Generators, field construction is held to a minimum. Most units are skid mounted and can be transported by rail, truck, or ship. The Wet Steam Generator is equipped with necessary controls and instrumentation to monitor operating pressures, flows, temperatures, etc., to protect personnel and equipment.

1.2 RATING

1.2.1 Wet Steam Generators are usually rated in millions of BTU's per hour of heat absorbed. They may also be rated by pounds per hour of steam, boiler horsepower, burner heat release capability, etc.

1.3 COMPONENTS

The basic parts of the Wet Steam Generator are as follows:

1.3.1 Feedwater System

Comprised of feedwater pumps and controls to provide a regulated quantity of water to a Wet Steam Generator.

1.3.2 Feedwater Preheater

Usually a double pipe heat exchanger. The heat source for this exchanger is normally taken from the convection section outlet. Its purpose is to elevate the inlet feedwater to a temperature above the flue gas dew point to prevent acid gas corrosion of carbon steel.

1.3.3 Convection Section

The last heat exchange area in the Wet Steam Generator to be exposed to the flue gases. The convection coil makes up most of the heating surface of the generator. The first tubes

exposed to the flue gas in the convection section are bare and are designed to reduce the gas temperatures prior to entering the finned section, and prevent luminous radiant heat on finned tubes. The convection section is normally a counter flow exchanger.

1.3.4 Radiant Section

Comprised of a combustion chamber with a serpentine radiant coil being the most common configuration. Here, the desired steam quality is obtained.

1.3.5 Fuel System

Wet Steam Generators burn a variety of fuels, the most common being natural gas or crude oil. The fuel gas system is designed with safety shutoff valves and pressure regulators. The fuel oil system normally includes safety shutoff valves, strainers, steam/oil heat exchanger, electric oil heater, pressure regulators, bypass systems, air and steam atomizing systems. The burner is designed for the required heat input, fuel and proper flame pattern.

1.3.6 Safety Equipment

Includes pressure relief and safety valves, flame safeguard equipment, and temperature, pressure and flow monitoring systems designed for safe equipment operation.

2 Specifications

2.1 This section establishes the minimum information to be furnished by the purchaser in order that minimum design, safety and environment considerations are established.

2.2 APPLICABLE AND STANDARDS

2.2.1 API

2.2.2 ASME

2.2.3 NEC

2.2.4 NFPA

2.2.5 EPA

2.2.6 ANSI

2.2.7 ASTM

2.2.8 OSHA

2.2.9 NEMA

2.2.10 State Codes

2.2.11 Local Codes

2.3 RATING AND EFFICIENCY

2.3.1 Wet Steam Generators should be rated in millions of BTU's per hour absorbed (MM BTU/Hr.) at the required discharge pressure (PSIG) and steam quality. Purchaser should specify that suppliers also state output capacity in pounds per hour of wet steam generated based on the feed-water temperature and desired steam quality specified by the purchaser.

2.3.2 Wet Steam Generator thermal efficiencies should be based on the higher heating value (HHV)* of the fuels to be burned, the specified exhaust gas temperature, and the excess oxygen or excess air in the flue gases.

2.3.3 Wet Steam Generator thermal efficiencies may also be based on the lower heating value (LHV)** of the fuels to be burned, the specified exhaust gas temperature, and the excess oxygen or excess air in the flue gases.

2.4 SPECIAL CONSIDERATIONS

Since each generator site is different, the following information should be supplied by the purchaser in the specifications to the vendor.

2.4.1 Fuel Oil Analysis—(See Table 1)

2.4.2 Fuel Gas Analysis—(See Table 2)

2.4.3 Other Fuels Analysis

2.4.4 Feedwater Analysis—(See Table 3)

2.4.5 Other Utilities Available

- a. Electrical Power ____ V. ____ Ph.
____ Hz.
b. Compressed Air: ____ SCFM ____ PSIG
____ Dew Point
c. Pilot Fuel: ____ Type ____ SCFM
____ PSI

2.4.6 Site Conditions

- a. Ambient Air Temp. °F: ____ Max.
____ Min. ____ Design
b. Wind Velocity, MPH: ____ Max.
____ Min. ____ Design
c. Elevation, Ft. Above Mean Sea Level:

- d. Seismic Zone: ____
e. Rainfall In./Yr.: ____ Avg.

*The higher heating value of a fuel is defined as the heat evolved, as measured by a constant pressure calorimeter, when a fuel is completely burned at stoichiometric conditions and the products of combustion are cooled to 60°F and the water vapor produced is completely condensed to liquid at that temperature. Heating values are reported in BTU/SCF for gaseous fuels, BTU/Lb. or BTU/Gal. for liquid fuels and BTU/Lb. for solid fuels.

**The lower heating value of a fuel is defined as the higher heating value minus the latent heat of vaporization of the water formed by the combustion of the hydrogen in the fuel. For a fuel with no hydrogen, the lower and higher heating values are the same.

f. Humidity %: ____ Max. ____ Min.
Design ____

g. Atmospheric Conditions
List unusual conditions such as H₂S,
Sand, Dust, Salt, Air, etc.

2.4.7 Environmental Considerations

- a. SO₂ Emission Limits,
PPM: ____ Current ____ Future
Lbs/Hr.: ____ Current ____ Future
b. NO_x Emission Limit,
PPM: ____ Current ____ Future
Lbs/Hr.: ____ Current ____ Future
c. Particulate Emission Limit,
Gr/SCF: ____ Current ____ Future
Lbs/Hr.: ____ Current ____ Future
d. Waste Liquid Emission Limits

2.4.8 Transportation

List unusual transportation restrictions such as Tunnels,
Narrow Or Weak Bridges, Restrictive Roads, etc.

Table 1—Fuel Oil Analysis

Higher Heating Value (HHV)	_____	BTU/Lb.
Lower Heating Value (LHV)	_____	BTU/Lb.
Density, 60°F	_____	Lb/Ft ³
or		
Specific Gravity, 60°F	_____	
or		
API Gravity, 60/60°F	_____	
Viscosity @ 60°F	_____	SSU
122°F	_____	SSU
200°F	_____	SSU
Other ____ °F	_____	SSU
Conradson Carbon Residue	_____	% Wt.
Ash	_____	% Wt.
Carbon (C)	_____	% Wt.
Hydrogen (H)	_____	% Wt.
Sulfur (S)	_____	% Wt.
Nitrogen (N)	_____	% Wt.
Water (H ₂ O)	_____	% Wt.
Sediment	_____	% Wt.
Vanadium (Va)	_____	mg/l
Iron (Fe)	_____	mg/l
Magnesium (Mg)	_____	mg/l
Sodium (Na)	_____	mg/l
Chloride as NaCl	_____	Lb/100 Bbl.

Table 2—Fuel Gas Analysis

	Natural Gas	
Higher Heat Value	_____	BTU/SCF
Lower Heat Value	_____	BTU/SCF
Molecular Weight	_____	
or		
Density, 60°F & 14.696 PSIA	_____	lb/Lb.
Temperature	_____	°F
Supply Pressure	_____	PSIG
Components (Mole %)		
Carbon Dioxide (CO ₂)	_____	%
Hydrogen Sulfide (H ₂ S)	_____	%
Nitrogen (N ₂)	_____	%
Oxygen (O ₂)	_____	%
Methane (CH ₄)	_____	%
Ethane (C ₂ H ₆)	_____	%
Propane (C ₃ H ₈)	_____	%
Butanes + (C ₄ +)	_____	%

Table 3—Water Analysis

Source:	_____
Pressure:	_____ PSIG
Temperature:	_____ °F (Min) _____ °F (Max)
Components	
*Calcium, (Ca)	_____ mg/l
*Magnesium, (Mg)	_____ mg/l
*Oxygen, (O ₂)	_____ mg/l
Barium, (Ba)	_____ mg/l
*Iron, (Fe)	_____ mg/l
*Sodium, (Na)	_____ mg/l
Copper, (Cu)	_____ mg/l
Potassium, (K)	_____ mg/l
Ammonium, (NH ₄)	_____ mg/l
*Chloride, (Cl)	_____ mg/l
Iodide, (I)	_____ mg/l
Bicarbonate, (HCO ₃)	_____ mg/l
Carbonate, (CO ₃)	_____ mg/l
Silica, (SiO ₂)	_____ mg/l
Sulfate, (SO ₄)	_____ mg/l
Hydroxide, (OH)	_____ mg/l
Hydrogen Sulfide (H ₂ S)	_____ mg/l
Organic Acids	_____ mg/l
*Total Alkalinity	_____ mg/l
*Total Hardness, (CaCO ₃)	_____ mg/l
*Total Dissolved Solids	_____ mg/l
*Total Suspended Solids	_____ mg/l
*pH _____ Specific Gravity @ 60°F _____	
Color _____	
*Oil _____ mg/l Resistivity @ 75°F _____ Ohm-meter	

*Minimum Data Required

2.4.8 Transportation

List unusual transportation restrictions such as Tunnels, Narrow Or Weak Bridges, Restrictive Roads, etc.

2.5 SAFETY EQUIPMENT

The following safety instrumentation and limit switches should be supplied for fully-automatic, unattended operation and for maximum safety of personnel and equipment.

2.5.1 Safety Instrumentation & Equipment

- ASME Code Required Safety Valve(s).
- Electronic Flame Monitoring Device and Combustion Controller including pre-purge, proof-of-pilot, proof-of-main flame, and post-purge sequence.
- Steam pressure controller
- Feedwater Flow Rate Transmitter & Controller
- Feedwater Pump Relief Valve
- Burner Firing Rate Controller
- Appropriate Temperature and Pressure Indicating Devices

2.5.2 Operating Safety Limits

The following safety limit devices are recommended, each limit should shut burner fuel valve(s) and require manual restart after malfunction:

- Flame Failure
- High Steam Pressure
- High Steam Pressure
- High Tube Temperature
- High Stack Temperature
- High Burner Throat Temperature (oil fired only)
- Burner Throat Switch (swing-out burners only)
- High/Low Atomizing Pressure (oil fired only)
- High Fuel Gas Pressure (gas fired only)
- Low Fuel Oil Pressure (oil fired only)
- Low Fuel Oil Temperature (oil fired only)
- Low Feedwater Flow Rate
- Low Combustion Air Pressure
- Low Instrument Air Pressure
- Low Steam Pressure
- Power Failure

2.6 AESTHETICS

Special consideration should be given to the locale of the Wet Steam Generator installation. The following should be considered:

2.6.1 Installation Housing

2.6.2 Installation Color Scheme

*Minimum required by Federal and most state codes. Others may be required by some states or insurance codes.

2.6.3 Noise Levels**2.6.4 Visible and/or Noxious Emissions****2.6.5 Other****2.7 HOOK-UP**

If special design considerations are required for connections, user should specify service, size, rating and location for the following.

2.7.1 Feedwater Inlet**2.7.2 Steam Outlet****2.7.3 Fuel Inlets****2.7.4 Electrical Connection****2.7.5 Other****3 Installation****3.1 INSPECTION FOR SHIPMENT DAMAGES**

3.1.1 Wet Steam Generators should be visibly checked for shipment damage and missing components immediately after delivery.

3.1.2 The Wet Steam Generator should be checked internally for refractory breakage.

3.1.3 All shipping damages should be reported to the carrier immediately.

3.2 FOUNDATION

3.2.1 Foundations for skid mounted Wet Steam Generators should be level and sufficient to support the weight of the Wet Steam Generator. Foundation loads are normally highest under the convection section.

3.2.2 Clearance must be provided for installing and servicing the Wet Steam Generator. Clearance space should include area required for replacing convection or radiant tubes and removal of complete component sections.

3.3 HEAVY LIFTING SERVICES

Lifting methods should be in accordance with manufacturer's recommendations.

3.4 REMOVAL OF SHIPMENT BRACES AND PROTECTIVE COVERS

Material installed to prevent enroute coil movement and all protective covers installed for shipping should be removed.

3.5 WATER AND STEAM CONNECTIONS

Consult manufacturer's installation drawings for connection sizes. All external piping should be same size or larger than Wet Steam Generator connections.

3.6 FUEL CONNECTIONS

3.6.1 Natural gas for gas fired units should be clean and free of liquids at the specified pressure. Sufficient volume should be provided upstream of safety shut off valves and inlet gas supply reducing regulator to provide a cushioning effect and reduce pressure surges. A relief valve should be installed on gas inlet supply piping if supply pressure can exceed safe working pressure or Wet Steam Generator gas train components.

3.6.2 Liquid fuels should be of consistent quality and void of free water, gas and sand. Heavy oil burners can operate satisfactorily with a small quantity of emulsified water. Manufacturer's specifications should be consulted for fuel oil inlet temperature, pressure and flow requirements. A return oil line from the Wet Steam Generator to the storage tank should be installed to provide for fuel oil circulation.

3.7 WASTE DISCHARGE CONNECTIONS

Wet Steam Generators may be supplied with individual drain connections or a central drain system and should be connected to an appropriate disposal system.

3.8 BLOW DOWN DISCHARGE CONNECTION

The Wet Steam Generator may be supplied with an optional blow down valve upstream of the outlet stop valve. End of the blow down line should be firmly anchored for discharge in an appropriate area.

3.9 PILOT FUEL CONNECTIONS

3.9.1 Wet Steam Generators require a pilot burner or other igniters to ignite the main burner. Pilot burner fuel normally is natural gas or LPG. Manufacturer's specifications should be followed for fuel gas supply.

3.9.2 Check pilot gas supply system for proper regulators to reduce pilot gas supply to specified pressure.

3.9.3 Light oil pilot burners may be used for special applications.

3.10 ELECTRICAL CONNECTIONS

3.10.1 Normally one power supply connection is made to the Wet Steam Generator. Manufacturer's specifications should be consulted for full load power supply requirements.

3.10.2 Manufacturers normally complete and test all electrical wiring before shipment. Wiring between skids and electrical components removed for shipment should be in ac-

cordance with manufacturer's specifications and all applicable codes.

3.10.3 Grounding connections should be installed between all applicable equipment and electrical systems to proper ground in accordance with manufacturer's specifications and all applicable codes.

3.10.4 Manufacturer's drawings and specifications should be checked for possible control wiring between Wet Steam Generator control panel and associated equipment.

3.11 AIR SUPPLY CONNECTIONS

Individual Wet Steam Generators are normally supplied with air compressor and filters for instrument and atomizing air supply. Wet Steam Generators for centralized locations without air compressors should be connected to an instrument and atomizing air supply system. Manufacturers specifications should be consulted for pressure, volume, and maximum moisture requirements.

3.12 MANUFACTURER SUPPLIED DATA

Manufacturer should supply purchaser with a Heat Balance Performance Data Sheet (See Figure 1) and Mechanical Data Sheet (See Table 4).

4 Commissioning

4.1 This section establishes the minimum procedures that should be adhered to by the user for initial start up of a new, or altered Wet Steam Generator, or one which has had an extended shut down. Manufacturer's recommendations should be followed for initial start-up and break-in procedures.

4.2 LUBE OIL LEVELS

Check lubrication oil level in feedwater pump and air compressor crank cases. Fill packing or rod lubricator reservoirs if provided. Special oil may be necessary to follow manufacturer's recommendations.

4.3 PULSATION DAMPENER CHARGE

Follow manufacturer's recommendations to check proper charge in pulsation dampers. Nitrogen charging system is required to increase charge pressure.

4.4 MOTORS

Make sure all motors are clean, dry, and serviceable. Follow manufacturer's instructions to check proper rotation.

4.5 COMPRESSOR

Table 4—Example Mechanical Design Data Sheet

Wet Steam Generator Model No. _____		Fuel _____	
Maximum Pressure _____ PSIG		Absorption Rate _____ BTU/Hr.	
Convection Section		Radiant Section	
Tube length (each) _____ Ft.		Tube length (each) _____ Ft.	
Number of bare tubes _____		Number _____ Size _____ In.	
Number of finned tubes _____		Number _____ Size _____ In.	
Effective Surface _____ Sq. Ft.		Effective Surface _____ Sq. Ft.	
Fin Configuration _____ In. High _____ In. Thick _____		Pins Per Foot _____	
Approximate Shipping Weight of Wet Steam Generator _____ Lbs.			
Approximate Weight of Radiant Section Assembly _____ Lbs.			
Approximate Weight of Convection Section Assembly _____ Lbs.			
Total Electrical Load _____ KVA		Largest Electric Motor _____ HP	
Thermal Design Specifications			
Inlet		Outlets	
Liquid _____	Lbs. Hr.	_____	Lbs. Hr.
Vapor _____	Lbs. Hr.	_____	Lbs. Hr.
Temperature _____	°F	_____	°F
Outlet Design Pressure _____		_____	PSIG
Enthalphy _____	BTU/Lb.	_____	BTU/Lb.
Burner Maximum Designed Heat Release _____ BTU/Hr.			

UNIT NO. _____ STATE SER. NO. _____

LOCATION _____

WATER ORIFICE PLATE SIZE _____

OIL FIRED _____ GAS FIRED _____

DATA BY _____

FLUE GAS

RATE _____ lb./Hr.

TEMP. _____ °F

PRESS DROP _____ In. of WATER

OXYGEN _____ %

GROSS EFF. _____ %

NET EFF. _____ %

RADIANT SECTION

DUTY: _____ BTU/Hr.

HEATING SURFACE _____ Sq. Ft.

AVG. HEAT FLUX _____ BTU/Hr./Sq. Ft.

AIR RATE _____ SCFM

RADIANT OUTPUT

PRESS _____ PSIG

TEMP. _____ °F

ENTHALPY _____ BTU/lb.

QUALITY _____ %

CONVECTION SECTION INPUT

PRESS _____ PSIG

TEMP. _____ °F

ENTHALPY _____ BTU/lb.

CONVECTION SECTION OUTPUT

PRESS _____ PSIG

TEMP. _____ °F

ENTHALPY _____ BTU/lb.

QUALITY _____ %

FEED WATER HEAT EXCHANGER

DUTY: _____ BTU/Hr.

RADIANT INPUT

PRESS _____ PSIG

TEMP. _____ °F

ENTHALPY _____ BTU/lb.

QUALITY _____ %

CONVECTION SECTION

DUTY _____ BTU/Hr.

HEATING SURFACE _____ Sq. Ft.

AVG. HEAT FLUX _____ BTU/Hr./Sq. Ft.

FEED WATER

PRESS _____ PSIG

TEMP. _____ °F

ENTHALPY _____ BTU/lb.

QUANTITY _____ GPM

_____ SCFD or GPM

_____ SPEC. GRAVITY

_____ BTU VALVE

_____ % SULFUR BY WT.

FUEL

Figure 1—Example Heat Balance Performance Data Sheet

4.5.1 Allow air compressor to build up to pressure cut off point. Set cut off switch if necessary. Bleed off pressure and check compressor cut in set point. Compressor must run long enough for proper lubrication as recommended by manufacturer.

4.5.2 Blow down pneumatic air lines at all filter drains and check for proper regulator operation.

4.6 WATER-STEAM PIPING SYSTEM

4.6.1 Open feedwater inlet and close steam outlet valves. Allow piping to fill with water from supply system and check for low pressure leaks. Open all vent valves or plugs at high points in piping system and bleed air.

4.6.2 Open blowdown or steam discharge valve and start feedwater pump. Observe pump operation at low pressure.

4.6.3 Test entire system for leaks up to working pressure following manufacturer's recommended procedure.

4.7 FUEL OIL SYSTEM

4.7.1 Follow recommendations to start separate fuel oil pumping and preheating unit if supplied. Fuel oil pumping and preheating unit should deliver fuel to Wet Steam Generator at specified temperature, pressure, and volume.

4.7.2 Set electric fuel oil heater thermostat to temperature required for proper atomization of fuel. Close hot water or steam valves to hot water or steam heated fuel oil heat exchanger.

4.7.3 Open manual fuel by-pass on Wet Steam Generator to start circulation. Close manual by-pass and set fuel back-pressure regulator.

4.7.4 Set burner fuel pressure regulator if fuel can be returned to supply downstream of regulator.

4.7.5 Adjust hot water or steam fuel oil heat exchanger control for desired fuel oil temperature when Wet Steam Generator is operating at temperature sufficient for heating fuel oil to proper atomizing temperature.

Set electric fuel oil heater thermostat slightly below required fuel oil atomizing temperature after hot water or steam fuel oil heat exchangers are operational.

4.7.6 Heavy fuel pumping and heating systems are normally left on at all times. Light oil fuel systems may be turned off when Wet Steam Generator is not firing.

4.8 FUEL GAS SYSTEM

4.8.1 Close Wet Steam Generator inlet manual gas valves. Open gas supply and check for proper supply pressure as specified by manufacturer.

4.8.2 Depending on the type gas burner supplied, manu-

facturer may supply a burner gas pressure regulator either upstream or downstream of safety fuel gas valves. If burner pressure regulator is upstream of safety valve, open inlet gas cock and set regulator according to manufacturer recommendations. Burner gas pressure regulator installed down stream of safety valves should be set as outlined in 4.9.9.

4.8.3 Check pilot gas supply system for proper regulators and adjust each regulator to specified pressures.

4.9 INITIAL FIRING

4.9.1 Check all valves to assure proper position for water flow through Wet Steam Generator.

4.9.2 Operate feedwater pump on manual control to insure water system is filled and flowing through the Wet Steam Generator.

4.9.3 Check that swingout type burners are secure. Check that combustion chamber manways are secure.

4.9.4 Operate combustion air blower on manual control, preferably with dampers open, to insure complete purge of combustion chamber.

4.9.5 Turn on fuel supply system if required.

4.9.6 Follow manufacturer's recommendations for initial setting of limit devices for initial firing of Wet Steam Generator.

4.9.7 Initial startup should be with pilot gas and main burner manual fuel valves closed. Normally, electrical control switches are turned to automatic position and a reset type start switch is activated to start a programed light off. The Wet Steam Generator should go through programed start-up. Combustion control system should lock out indicating flame failure due to no pilot flame with pilot fuel valves closed.

4.9.8 Reset combustion control system, open pilot gas supply, place burner control in low fire hold and restart system with main burner manual fuel valve closed. Burner pilot should ignite, the combustion control system should indicate pilot flame and permit safety fuel valves to open. Flame failure indication should occur when pilot flame times out without lighting main burner due to closed main burner fuel valves. Adjust the pilot burner in accordance with Wet Steam Generator manufacturer instructions.

4.9.9 Reset combustion control system, open both pilot and main burner manual fuel valves. Restart system with burner control in low fire hold position. Observe flame and adjust burner and fuel pressure regulators in accordance with manufacturer's instructions for low fire operations.

4.10 DRYING OUT REFRACTORY

Follow manufacturer's recommendations for drying refractory on initial startup if applicable. Initial refractory dry-

ing is normally at low fuel and high excess combustion air rates to reduce flue gas condensation at low firing rates.

4.11 HIGH RATE BURNER ADJUSTMENTS

4.11.1 The burner operator device normally controls combustion air dampers. Fuel rate control normally is through adjustable linkage attached to the air dampers or, on special applications, by separate operators. Differential pressure regulators are often used to increase either fuel or atomizing air-steam pressure as firing rates increase.

4.11.2 The Wet Steam Generator should be run at rated capacity to set air dampers and fuel valves at maximum firing rate. The linkage system should be adjusted so burner fuel control valves and air dampers at full firing rate will permit maximum travel of the burner operator and positioner. Fuel rate on liquid fueled units and gas burner nozzle pressure on gas fired units should be noted at full firing rate for future reference when adjusting burner positioner.

4.11.3 After setting air-fuel for proper ratio at high fire rate, the burner should be reduced in steps to lower rates and air-fuel ratios checked. Adjustments may be required to provide proper air-fuel ratios over the desired firing rate range.

4.12 BURNER POSITIONER

4.12.1 The burner positioner characterizes burner travel and firing rate in relation to burner control signal. The burner control signal may be manually controlled or automatically modulated in relation to feedwater rate depending on control system design. A biasing regulator may be used to add or subtract a constant control signal to or from a feedwater flow rate signal to provide a modulating burner control signal.

4.12.2 Burner positioners on modulating type units should be set to provide the highest desired steam quality at highest feedwater and firing rates.

4.12.3 Outlet steam quality should be used to set and check burner firing rate in relation to feedwater rate. Water-fuel rate ratios in relation to outlet steam quality may be used to adjust burner positioners for firing rate to feedwater rate.

4.13 SAFETY SHUT DOWN DEVICES

All safety limit devices should be set and checked for both mechanical operation and electrical shut down of the Wet Steam Generator for unattended operation.

4.14 FLOW-PRESSURE BURNER CONTROLS

Set water flow rate controls, outlet steam pressure controls and trim burner controls if necessary for desired operating parameters prior to unattended operation.

4.15 EFFICIENCY CHECK

Heat balance performance data can be gathered and efficiency calculated after initial start up and periodically as desired. (See Figure 1.)

5 Operations

5.1 This section establishes the minimum procedures for the start-up, on-stream adjustment, and shutdown of existing Wet Steam Generator systems.

5.2 START-UP PROCEDURES

5.2.1 The start-up procedure may vary with the type of Wet Steam Generator, the control system, and individual preferences or requirements of the operating company. The control system initiates light off of the burner in a pre-set sequence of events, if all limit conditions are safe, and will prevent the main fuel valve from opening if an unsafe condition exists.

5.2.2 The control system should initiate the start-up sequence by modulating the burner blower control to high purge position, purging the Wet Steam Generator of combustible gases, and allowing the tubes to fill with water. After a predetermined time, the burner blower should modulate to low fire position. If all limits are completed, the pilot is ignited and the ultra violet (UV) flame scanner confirms flame, permitting firing of the main burner. *Manual programming override or bypassing of safety limits should never be executed.*

5.2.3 Pre-Start Check List

Before the Wet Steam Generator is started, the following items should be checked and the manufacturer's start-up instructions reviewed. If the unit has been in prolonged storage, commissioning procedures should be followed as described in Section 4.

- a. Check that all personnel are clear and all access openings properly closed, and Wet Steam Generator interior is free of residual fuel or debris.
- b. Place all control switches in the off position. Turn on main electrical power supply switch and follow manufacturer's start-up sequence.
- c. Check that the following utilities are available at the Wet Steam Generator: electricity, treated feed water, fuel gas or heated fuel oil, pilot gas, instrument air, and atomizing air or steam if firing fuel oil.
- d. Check that the water and steam valves are opened for a clear path through the Wet Steam Generator.
- e. Check that the blowdown valve (if provided) directs the water-steam flow to the blowdown area.
- f. Check that there is an open pipeline to an injection well and that no one is working on the piping system or well.
- g. Check that the fuel oil (if used) is at the proper operating temperature and pressure at the burner.

h. Run the feed water system in the manual mode until a full stream of water is flowing through the Wet Steam Generator.

5.2.4 Start-Up

After being sure that the above and any other necessary steps have been properly completed, prepare to start the Wet Steam Generator. With control power on and all appropriate switches in on/automatic position, reset the combustion control system. With most control systems the following sequence of events should occur.

- a. The feed water flow is established satisfying the low water flow limit.
- b. The main blower starts satisfying the low combustion air limit.
- c. The unit will cycle to the high purge position and should provide a minimum of four firebox volumes of air displacements.
- d. The burner will return to the low fire position and the burner low fire interlock must be satisfied for ignition sequence to continue.
- e. The ignitor is energized and the pilot fuel valve opens.
- f. The UV flame scanner must prove the pilot flame.
- g. With the pilot confirmed the safety fuel valve(s) can be opened. The safety fuel valve(s) may be designed for automatic or manual operation.
- h. Flame scanner must prove the main flame.
- i. The control system should sequence to the normal fire position and allow the burner firing rate to be controlled manually or automatically.
- j. When suitable atomizing steam is available, atomization should be switched to steam.
- k. When the desired operation conditions are met, discharge steam should be opened to injection system and then the blowdown valve(s) closed.

5.2.5 If a safety limit condition is exceeded, the fuel safety valve(s) will close and the control system will initiate post purge sequence.

5.3 ADJUSTING THE WET STEAM GENERATOR FOR UNATTENDED OPERATION

5.3.1 In order that the Wet Steam Generator operate unattended in a safe, stable, and efficient manner, it must be properly adjusted.

5.3.2 Flame Condition

The flame shall be adjusted to minimize impingement on tubes or tube hangers causing "hot spots." A clean fuel nozzle, radiant section pressure, and the air-fuel ratio contribute to a good flame pattern. For oil fired burners the proper fuel pressure and viscosity, and suitable atomizing steam-air pressure and quality are also significant factors.

5.3.3 Operating Pressure

If the Wet Steam Generator's maximum output is greater than the injection well's capacity, the output must be reduced so a maximum pressure is not exceeded. Both the water and firing rates must be reduced.

5.3.4 Water to Fuel Ratio

The steam quality is established by the water to fuel ratio. This ratio must be high enough to prevent excessive concentration of dissolved solids in the liquid phase which can cause tube wall scaling (See Appendix A.2.2). The ratio must also be low enough so that sufficient enthalpy leaves the Wet Steam Generator. The most common practice is to limit steam quality to 80%. The operating water-fuel ratio or steam quality should be checked and adjusted by the operator periodically.

5.3.5 Water Temperature to the Convection Section

The water temperature to the convection section inlet should be high enough to prevent flue gas condensate corrosion of the convection section.

5.3.6 Thermal Efficiency

Thermal efficiency is dependent on design and operation. Controlling excess oxygen at a low value and maintaining minimum stack temperature with periodic convection section cleaning maintains high thermal efficiency. Daily logs of pressure in the radiant section or increased flue gas temperature may indicate fouling in the convection section.

5.3.7 Safety Checks

The safety shutdown devices must be operational and checked periodically in accordance with the state or local regulations and manufacturer/operator recommendations. The safety limits are designed to close the fuel safety valve and cause the Wet Steam Generator to shut down if a safety limit is exceeded. They will also prevent the pilot or main burner from lighting if an unsafe condition exists. The safety limits may be set close to the operating point and are generally set at the closest point that will not cause frequent nuisance shutdowns or at the maximum limit for safe operation.

5.4 SHUTDOWN PROCEDURES

5.4.1 Normal Shutdown

If the Wet Steam Generator is to be shut down for a routine reason, the burner on/off switch may be used. However, the preferred method is to trip a safety limit that does not interfere with the post purge cycle. An unattended shutdown can be simulated by a limit switch set point or an operating parameter change. This will check the proper operation of the limit shutdown, the first outage indicator, and the post purge blower and feed water pump timers.

5.4.2 Emergency Shutdown

A prominent switch should be provided on the control panel and, if necessary, a safe distance from the Wet Steam Generator to kill the control (110 volt) power that operates the main motor starters. The high voltage main switch can then be opened without a load. *These procedures should only be used when normal shutdown cannot be safely conducted.* Provision to shut off the fuel supply should be provided remotely in case of fire. A fire detection system to shut off the fuel supply may also be provided.

5.4.3 Prolonged Shutdown

If the Wet Steam Generator is to be shut down for a prolonged time, the following minimum steps should be taken for equipment protection.

- a. Drain the water from the tubes and close the valves to exclude air.
- b. Drain and purge all systems which may contain moisture.
- c. If the Wet Steam Generator is fired with heavy oil, displace the heavy oil in the fuel system with light oil.
- d. Protect the pneumatic and electric instruments from the elements.
- e. Remove the main electric supply fuses or breakers and take steps to prevent unauthorized operation.
- f. Place a cover over the stack to protect the interior from the elements. Place a cover over the blower intake.
- g. Review manufacturer's recommendation for prolonged shutdown and storage.

6 Maintenance

6.1 It is recommended that maintenance and inspection procedures be performed daily, monthly and annually. All repairs and maintenance should be documented. The manufacturer's recommendations should always be a part of maintenance and inspection, and forms should be designed for each specific application. (Figure 1 and 2 and Tables 4, 5, 6 and 8 are offered as a guide to record the events.) Consider the environment in which a generator operates. Severe environments may require special maintenance and inspection.

6.2 DAILY MAINTENANCE AND INSPECTION

6.2.1 A minimum daily routine of inspecting and recording of all instrument readings is recommended and the following is a list of the minimum readings that should be recorded: (See Table 5)

- a. Feedwater pump discharge pressure
- b. Feedwater flow rate
- c. Steam outlet pressure
- d. Steam outlet temperature
- e. Water inlet temperature
- f. Radiant tube skin temperature

- g. Fuel nozzle pressure
- h. Stack temperature
- i. Radiant section pressure
- j. Fuel rate
- k. Excess air or O_2

6.2.2 In addition there are other parameters that require testing, calculations, or judgment and should also be monitored and recorded. The following items are recommended:

- a. Water quality (See Appendix A)
- b. Steam quality
- c. Flame pattern
- d. Visual internal and external inspection
- e. Lubricating oil levels of the feedwater pump power end
- f. Lubricating oil level of the air compressor
- g. Filter and strainer efficiency

6.3 MONTHLY MAINTENANCE AND INSPECTION (See Table 6)

6.3.1 Feedwater pump, fluid and power ends and drive systems should be inspected. The manufacturer's recommended maintenance procedures should be followed. The crankcase oil should be inspected and replaced as specified by the manufacturer.

6.3.2 All motors should be inspected and lubricated as specified by the manufacturer.

6.3.3 Fuel, water, air strainers and filters should be cleaned and serviced, as required.

6.3.4 If the Wet Steam Generator is shut down the condition of the convection section and radiant section tubes should be noted. Fin loss deterioration or fouling should be noted and recorded.

6.3.5 If the Wet Steam Generator is shut down, the flame stabilizer/diffuser and fuel nozzle, used with heavy oil burners should be inspected and cleaned as required.

6.4 SAFETY INSPECTION (See Table 8)

6.4.1 It is recommended that all safety devices be tested at a minimum of once each sixty days. State and local codes may require more frequent testing.

6.4.2 Some regulations require a minimum of five safety shutdown devices to be responsive.

- a. High steam pressure
- b. High tube temperature
- c. Flame failure
- d. Low combustion
- e. Low feedwater flow rate

6.4.3 Most manufacturers and purchasing companies require additional safeties, and local codes may require others. Any additional safeties should be tested and the results recorded.

6.4.4 Where possible always test both the electrical and sensing portions of any safety device.

6.4.5 Any safety that does not function must be replaced or repaired.

6.4.6 The following is a listing of the safety devices that should be tested each 60 days.

- a. Flame failure
- b. High steam temperature
- c. High steam pressure
- d. High tube temperature
- e. High stack temperature
- f. High burner throat temperature (oil fired only)
- g. Swing out burner switch
- h. High/Low atomizing pressure (oil fired only)
- i. High fuel gas pressure
- j. Low fuel pressure
- k. Low fuel oil temperature
- l. Low feedwater flow rate
- m. Low combustion air pressure
- n. Low instrument air pressure
- o. Low steam pressure

6.5 ANNUAL MAINTENANCE AND INSPECTION (See Exhibit 6.4.)

6.5.1 Permanent and progressive records should be maintained for each Wet Steam Generator. It is recommended that the following documents and information be included:

- a. All ASME Manufacturers' Data Reports.
- b. Drawings showing the location and thickness of monitored or critical inspection locations.
- c. If material loss is found within the piping system the maximum allowable working pressure and temperature should be recomputed by a qualified person and the Wet Steam Generator derated or repaired accordingly. All calculations should be made a part of the annual record. All name plates, permits, etc., must reflect the change. In addition, a name plate rubbing should be included in the records.
- d. Hydrotest the steam piping from the feedwater pump discharge to the steam outlet at the time of inspections. If applicable record the hydrotest pressure.
- e. Schedule date of next inspections.
- f. Date of any significant changes in service conditions.
- g. Complete pressure relieving device information including safety relief valve spring data and dates of latest and next inspection.

h. The completion of a performance data sheet (Figure 1) is recommended. The data can be a useful inspection/maintenance tool.

i. The Wet Steam Generator Mechanical Design Data Sheet (Table 4) should be completed and become a part of the initial records. It should be checked and updated annually to reflect any changes.

6.5.2 A safety check should coincide with an annual maintenance procedure and in addition to the items inspected daily and monthly, the following points should be inspected for proper annual maintenance:

a. External Inspections. Any evidence of steam or water leaks should be investigated. Leakage from behind insulation, coverings or supports should be investigated and corrective action taken.

1. All pressure and temperature instruments should be calibrated and replaced as required.

2. Safety relief valves should be carefully examined at each inspection and there should be no accumulations of rust, scale or other foreign substance in the valve body which will interfere with the free operation of the valve. It is recommended that annually the safety valves be removed from the unit, tested and reset at an approved safety valve testing facility or by the valve manufacturer. State or local regulations may require more frequent inspection or testing.

3. Electrical. The continuity and condition of all electrical components should be checked.

b. Internal Inspections. Where there is evidence of insulation or refractory failure the material should be repaired or replaced.

1. The surface of all tubes should be carefully examined for any evidence of corrosion, erosion, deformation, bulging, sagging, cracks or defective welds. The radiant coil or tubes and the convection section should be spot checked for wall thickness by a non-destructive test. If repairs are made to the code sections of the Wet Steam Generator, a record of the repair must be made. A partial data sheet, ASME form P-3 for the material or piping used, is to accompany the repair form. (See Table 10)

2. Tube hangers, yokes and hanger bolts should be inspected for thinning, cracking, stress or deformation.

3. THE HYDROSTATIC TEST PRESSURE SHOULD BE 1½ TIMES THE MAXIMUM ALLOWABLE WORKING PRESSURE AND SAFETY PRECAUTIONS MUST BE EXERCISED.

Table 7

1. Refer to Exhibit 6.4.
2. Keep all motors clean and ventilation openings clear of dust, dirt and other debris. Do not over grease.
WARNING: Disconnect all power sources to the unit and discharge all parts which may retain an electrical charge before attempting any maintenance or repair. Screens and covers must be maintained in place when unit is in operation.
 Some small motors have sealed-for-life type bearings which require no relubrication.
 Motors that do require lubrication, can be regreased by stopping the motor, removing the drain plug and pumping new grease into fillhole. Run the motor with the drain plug removed, for a short period, to discharge excess grease. Replace the drain plug.
 Motors that operate at speeds greater than 1800 RPM should be lubricated on a more frequent maintenance schedule depending on duty cycle.
3. On occasion it may be necessary to remove deposits from between the fins on the tubes in the convection section. The frequency of cleaning the fin tubes will be determined by the type of fuel oil being used.
 The convection section fin tubes may require cleaning when increase in back pressure of approximately 2" w.c., above new and clean condition, is indicated on the radiant section manometer.
4. The frequency of service required for the filters and strainers is determined by operating time using fuel oil and the quality of the fuel oil being used.
 One indication of a dirty element is a drop in oil pressure to the burner (as indicated on pressure gauge).

Table 8—Wet Steam Generator Safety Inspection Check Sheet

Unit No.	State Serial No.	Inspection Date
Make of Unit & Fuel Used	Location	Inspector's Signature
1. Enter OK or failed in column headed "Proper Operation" 2. Enter set point of control in column headed "Set Point" 3. Describe any safety failure under "Comments" and describe repairs made 4. Draw line through any safety listed that is not on this unit		
Shutdown	Proper Operation	Set Point
High Steam Pressure		
High Tube Temperature		
High Steam Temperature		
Flame Failure		
Low Combustion Air Pressure		
Low Water Flow		
Low Fuel Pressure		
High Fuel Gas Pressure		
Low Steam Pressure		
Low Instrument Air		
Burner Throat Temperature		
Swing Out Burner Switch		
High Stack Temperature		
Low Atomizing Pressure		
Low Fuel Oil Temperature		
Safety Relief Valves*		

Visual check of external wiring, conduit, piping, tubing and fittings for obvious leaks or defects. All gauges must be checked for proper calibration.

*Consult state and local codes for test procedures.

Electrician	Date
Mechanic	Date
Operator	Date
Foreman	Date




Figure 2

Table 9—Wet Steam Generator Annual Check List

Item No.	Description of Item	Inspected		Condition			Comments
		Yes	No	OK	Faulty	Replaced	
	WATER FLOW SYSTEM						
A-1	Water Inlet Flange						
A-3	Suction Dampener						
A-3a	Isolation Valve						
A-4	Water Inlet Drain Valve						
A-5	Cooling Coil Valve						
A-6	Feedwater Pump						
A-8	Oil Level Control						
A-9	Oil Reservoir						
A-10	Pump Motor						
A-10a	Belt Guard						
A-11	Pump By-Pass						
A-12	Pump Relief Valve						
A-13	Discharge Dampener						
A-14	Feedwater Orifice						
A-15	Feedwater Flow Record						
A-16	Inlet Check Valve						
A-17	Inlet Stop Valve						
A-18	Feedwater Preheater						
A-18a	By-Pass Valves						
A-19	Diverting Orifice						
A-20	Radiant Coil Vent Valve						
A-21	Steam Discharge Separator						
A-22a	Safety Valve						
A-22b	Safety Valve						
A-27	Pressure Gauges						
A-28	Pressure Gauge Valve						
A-29	Pressure Gauge Test Valve						
A-30	Vent Valve						
A-31	Cooling Coil Valve						
A-32	Drain Valves						
A-34	Thermometer with Socket						
A-35	Convection Section						
A-36	Stop/Check Valve(s)						
A-39	Sample Cooler						
A-40	Radiant Section						
A-41	Blowdown Valve						
	ANNUNCIATOR PANEL						
B-1	Flame Monitor						
B-2	High Steam Temp.						
B-4	High Tube Temp.						
B-5	High Stack Temp.						
B-6	High Burner Temp.						
B-7	Low Oil Temp.						
B-8	High Steam Press.						
B-10	High Atom. Press.						
B-11	Low Atom. Press.						
B-12	Low Gas Press.						
B-15	Low Oil Press.						
B-16	Low Instrument Air Press.						
B-17	Low Combustion Air Press.						
	PNEUMATIC SYSTEM						
C-1	Air Compressor						
C-2	Air Receiver Tank						
C-4	High/Low Press. Switch						
C-5	Air Relief Valve						
C-6	Pressure Gauge						
C-7	Gauge Valve						
C-9	Instrument Air Filter						
C-10	Air Pressure Regulator						
C-11	Air Pressure Regulator						
C-12	Pneumatic Transmitter						
C-12a	Transmitter Valve Manifold						
C-13	Water Flow Rate Gauge						
C-14	Burner Control Signal						

Table 9—Wet Steam Generator Annual Check List (Continued)

Item No.	Description of Item	Inspected		Condition			Comments
		Yes	No	OK	Faulty	Replaced	
C-15	Flow Purge Solenoid						
C-16	High Purge Solenoid						
C-17	Low Fire Solenoid						
C-18	High Signal Selector						
C-19	Manual Loader (Water)						
C-20	Bias Regulator (Burner)						
C-21	Burner Operator w/Positioner						
C-22	Pressure Controller						
	MAIN GAS SYSTEM						
E-1	Gas Inlet						
E-2	Manual Gas Stop Valve						
E-3	Safety Shut Off Valves						
E-4	Vent Valve						
E-5	Gas Pressure Regulator						
E-10	Gas Orifice Flanges						
	PILOT GAS SYSTEM						
E-13	Manual Pilot Gas Stop Valve						
E-14	Pilot Regulator						
E-15	Pilot Solenoid Valve						
	FUEL OIL PIPING						
F-1	Oil Inlet Valve						
F-2	Oil Strainer						
F-3	Manual Bypass Valve						
F-4	Oil Pressure Relief Valve						
F-5	Steam/Oil Heater						
F-6	Temp. Control Valve						
F-6a	Temp. Controller						
F-6b	Pneumatic Valve						
F-7	Electric Oil Heater						
F-8	Oil Pressure Regulator						
F-9	Thermometer						
F-10	Oil Return Valve						
F-11	Oil Meter						
F-11a	Oil Meter Valves						
F-12	Pressure Gauge						
F-13	Gauge Valve						
F-14	Burner Oil Valve						
F-14a	Solenoid Valve						
	ATOMIZING AIR SYSTEM						
G-1	Air Stop Valve						
G-2	Air Pressure Regulator						
G-3	Air Solenoid Valve						
G-4	Air Check Valve						
	ATOMIZING STEAM SYSTEM						
H-1	Steam Stop Valve						
H-2	Primary Steam Regulator						
H-4	Pressure Gauge						
H-5	Steam Separator						
H-6	Steam Press. Relief Valve						
H-7	Steam Trap						
H-8	Secondary Steam Regulator						
H-9	Steam Solenoid Valve						
H-10	Steam Check Valves						
	BURNER						
J-1	Burner						
J-2	Blower Motor						
J-3	Flame Stabilizer/Diffusers Plate						
	MISCELLANEOUS						
K-4	Observation Ports						
K-6	Manometer						

Table 10—Record of Welded Repairs

This is to certify that the fusion-welded repair made by and under the direction of the undersigned on _____
and consisting of _____ (Date of Repair)

(Description of Repair)

Unit No.	Name of Original Manufacturer	State No.	Natl. Bd. or Serial No.	Year Built
Location _____				

(Owner or Company)

Welding was done by _____
(Name of Qualified Welder)

(Note: Draw a sketch to show the repairs on back)

Name of Repair Firm _____

Signed By _____ Date _____

Address _____

Date _____

(Authorized Inspector's Signature)

(Name of Inspection Agency Employed By)

APPENDIX A—WET STEAM GENERATOR FEEDWATER QUALITY

A.1

Feedwater quality is a critical factor to the good operation of the Wet Steam Generator. Poor quality feedwater can result in tube failures. Problems in Wet Steam Generator Systems as a result of poor feedwater quality can normally be categorized in the following areas:

A.1.1 SCALING

The production of adherent solid deposits which can enhance corrosion and cause localized over heating and poor heat transfer.

A.1.2 SOLIDS

The production of suspended solids which are undesirable as solids carryover.

A.1.3 CORROSION

The chemical attack causing oxidation of metal surfaces in contact with the feedwater.

A.2

The following factors should be considered in the treatment of feedwater:

A.2.1 TOTAL HARDNESS

To avoid operating problems, it is necessary to soften the Wet Steam Generator feedwater to less than one part per million (ppm) total hardness. Calcium, magnesium and iron ions are the most common causes of Wet Steam Generator scale.

Iron concentrations should be held below 0.1 ppm to prevent scaling. If high silica levels are present in the feedwater lower concentrations may be required to prevent premature scaling.

A.2.2 TOTAL DISSOLVED SOLIDS (TDS)

Levels of TDS in Wet Steam Generator operation become a cause for concern only when liquid phase concentrations approach solubility limits. Therefore, a unit producing 80% quality steam should be able to tolerate feedwater dissolved solids in concentrations approaching 20% of their solubility limits. For example, sodium chloride levels of 60,000 ppm are possible. At extremely high TDS levels, control of corrosion producing oxidants and scale forming materials such as total hardness becomes critical.

The practical limitation on TDS generally comes as a result of water softener operating limitations. Most softening is done with cation resin exchange systems because of their reliability and simplicity of operation. Most softeners utilize salt regenerated sulfonate (strong acid) resins whose hardness leakage characteristics limit their operation to approxi-

mately 7000 ppm TDS. Recently developed weak acid resins are able to function at TDS levels up to approximately 30,000 ppm; however, both the capital and operating costs of these resins are several times that of the strong acid resins.

A.2.3 SUSPENDED SOLIDS

Suspended solids contribute to softener fouling and sludge formation. Filtration of the feedwater to reduce suspended solids levels below 5 ppm and preferably below 1 ppm is recommended.

A.2.4 OIL

Oil contributes to scaling adherence, film boiling and coking. Ion exchange resins are quite prone to oil fouling and tend to remove most feedwater oil at the expense of resin life. To minimize softener fouling a suspended oil content below 1 ppm is recommended.

A.2.5 OXYGEN

Oxygen is a corrosion accelerator. Oxygen exclusion, deaeration, and chemical scavenging can be used to maintain oxygen levels as low as possible. Recommended maximum oxygen residuals should be less than 0.01 ppm and preferable 0.0 ppm. In practice, a residual level of scavenging chemical is usually maintained.

A.2.6 ALKALINITY

Alkalinity is primarily the result of carbonates in the feedwater and may be influenced by addition of hydroxides and sulfites. Although excess hydroxide alkalinity can contribute to caustic embrittlement, moderate alkalinity levels help reduce corrosion and maintain silica solubility. Bicarbonate alkalinity levels of over 2000 ppm should be avoided due to excess hydroxide production.

A.2.7 SILICA

Control of silica problems in Wet Steam Generator systems consists primarily of maintaining solubility. Silica solubility is strongly affected by alkalinity. Alkalinity should be maintained at least three times the silica content. Satisfactory operations with silica contents of 150 ppm are possible in the absence of scaling ions.

A.2.8 PH

The pH level of feedwater is related both to its potential for acid corrosion and alkalinity. Acceptable operation has been obtained at pH values from 7 to 12. Lower values indicate possible acidic corrosion while values of 13 or above indicate excess hydroxide alkalinity with both caustic corrosion and caustic embrittlement possible.

APPENDIX B—WET STEAM GENERATOR EMISSIONS CONTROL

B.1 Flue Gas Emissions

Concerns regarding fired equipment emissions to the environment has resulted in changes to Wet Steam Generator systems. Equipment and design modifications are used to control these emissions. Concerns center on particulates, the oxide of sulfur and oxides of nitrogen.

B.2 Control of Particulates

Some methods of control are:

- B.2.1** Wet electrostatic precipitators
- B.2.2** Dry electrostatic precipitators
- B.2.3** Venturi sections in conjunction with wet scrubbers
- B.2.4** Bag house filters

B.3 Control of Oxides of Sulfur

Some methods of control are:

- B.3.1** Use of low sulfur fuels

- B.3.2** Treatment of high sulfur fuels to reduce the sulfur content

B.3.3 Wet scrubbing of flue gas to remove oxides of sulfur formed in the combustion process. Some types of wet scrubbing systems are:

- a. Single-alkali process
 - 1. Caustic scrubbing
 - 2. Soda ash scrubbing
- b. Double-alkali process

B.4 Control of Oxide of Nitrogen

Some methods of control include both physical and chemical techniques. These are:

- B.4.1** Excess air control
- B.4.2** Low oxides of nitrogen burners (low NO_x burners)
- B.4.3** Flue gas recirculation
- B.4.4** Ammonia injection
- B.4.5** Catalytic conversion

APPENDIX C—WET STEAM GENERATOR FUEL OIL

C.1

Most fuel oils being used in Wet Steam Generators must be conditioned to provide viscosities not exceeding 100 to

150 SSU at the burner. If oil must be heated, electric or steam-water heaters are commonly used. Manufacturer's recommendation should be consulted to determine the proper operating viscosity.

APPENDIX D—FACTORS FOR CONVERSION TO INTERNATIONAL SYSTEM OF UNITS (SI)

Customary Unit	API Preferred Metric Unit ¹	Conversion Factor (Multiply Quantity Expressed in Customary Units by Factor to Get Metric Equivalent)	
BTU/Hr.	kJ/h	1.055 056	E+00
BTU/SCF	kJ/m ³	3.725 895	E+01
BTU/Lb	kJ/kg	2.326 000	E+00
BTU/Gal	kJ/m ³	7.742 119	E-02
Lbs/Hr	kg/h	4.535 924	E-01
Lbs/Ft ³	kg/m ³	1.601 846	E+01
Lbs/1000 Bbl	g/m ³	2.853 010	E+00
Gr/CF	mg/m ³	2.288 352	E+03
Ft ³ /Lb	m ³ /kg	6.242 796	E-02
In/Yr	mm/a	2.54	E+01
MPH	km/h	1.609 344	E+00
CFM	dm ³ /s	4.719 474	E-01
PSI	kPa	6.894	E+00
°F	°C	(°F-32)/1.8	

¹Based on API Publication 2564, Manual of Petroleum Measurement Standards Chapter 15-Guidelines for Use of the International System of Units (SI) in the Petroleum and Allied Industries. December 1980.

API RP*11T 94 ■ 0732290 0539120 152 ■

9/94—2M (Johnston)

ADDITIONAL COPIES AVAILABLE FROM
PUBLICATIONS AND DISTRIBUTION
(202) 682-8375

American Petroleum Institute
1220 L Street, Northwest
Washington, D.C. 20005



Order No. 811-11T02